


# MAINTENANCE REGISTERS & LOG BOOK

## ELECTRICAL AND PLUMBING MAINTENANCE REGISTER

	5388	5/11/19	College 2 floor toilets Toilet of ladies toilet room water pipe broke 2 floor and wash water pipe broke wash, block removed work is completed.		5394	16/11/19	Boys hostel 2 floor corridor light 2 nos. Replament and bed room tube light 2 nos. (Set). Replament work and toilet room house light 1 set Replament work (Cross tube light fitting)		
	5389	5/11/19	College ground floor Guest Toilet room Floor Bell valve change work work is completed.		5395	16/11/19	Room no 57/55 tube light Replament work work is completed.		
	5390	15/11/19	2 floor College Ladies Toilet 2 room water not coming for pipe block work block work (removed) is Completed.		5396	16/11/19	Room block work college College		
	5391	15/11/19	Boys Hostel 2 floor Corridor (Opp side) 2 tube changes and bed room and toilet room 2 tube light set Replament work work is completed.		5397	16/11/19	Conference room up side fan 2 switch box work room fan fixed on system used in room work.		
					5398	18/11/19	ortho dept RA side fan 2 tube light change plaster for work is Completed.		



Tagore dental college and hospital, Rathinamangalam, Tamil Nadu 600048, India

**Rathinamangalam**  
Tamil Nadu  
India

2019-11-20(Wed) 14:41

31°C  
88°F

## EQUIPMENTS AND INSTRUMENTS MAINTENANCE REGISTER

11/11/19 Dept of Para...  
Dental chair / X-ray / Station Ground checkup +  
Demonstration work working good.

12/11/19 Dept of Para...  
Dental chair not working (operation)  
mm. 10080222 checked the chair Motor E. Drive bottom  
to be change. No E. Drive replace to cap / wire.

13/11/19 Dept of Para...  
Dental chair not working. Checked the tube, wire working  
good.

14/11/19 Dept of Para...  
Dental chair in factory. Checked the wire tube. Check  
out of the tube. Check the wire. Change.  
Tensioning wire. Not open. Check for the alloy in the  
chain. open / closing. Refractory.

15/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Fixed  
Spring in Transformer. For the wire. Fixed. Working good.

16/11/19 Dept of Para...  
Changed wiring in the. Spring valve. Replaced. New one  
fitting.

17/11/19 Dept of Para...  
Dental chair not working. Checked & replaced the  
Refractory. Check the wire. Working good.

18/11/19 Dept of Para...  
Dental chair not working. Checked the wire. For being  
the wire. Change the wire.

19/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

20/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

21/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

22/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

23/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

24/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

25/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.


26/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

27/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

28/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

29/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.

30/11/19 Dept of Para...  
Dental chair not working. Checked the wire. Spring wire. Replaced.  
Working the wire. Working good.



Tagore dental college and hospital, Rathinamangalam, Tamil Nadu 600048, India

**Rathinamangalam**  
Tamil Nadu  
India

2019-11-21(Thu) 10:42

29°C  
84°F

**EQUIPMENT MAINTENANCE CARD :**

**TAGORE DENTAL COLLEGE & HOSPITAL**  
RATHINAMANGALAM, MELAKKOTTAIYUR POST, CHENNAI - 600 127.


**EQUIPMENT MAINTENANCE CARD**

NAME OF THE DEPARTMENT : PERIODONTICS.  
 NAME OF THE EQUIPMENT : COMPUTER DESKTOP SYSTEM  
 DATE OF PURCHASE : 23-06-200.  
 NAME OF THE MANUFACTURER : ACER (LLS INFOTECH LTD)  
 MANUFACTURER'S SERIAL No. : MONITOR: C1LLCDD003008062A19001  
 CPU: VX13045126121  
 UPS: V021500011261

DATE	COMPLAINT / SERVICE DONE	TECHNICIAN SIGN	INCHARGE SIGN
27-07-15	UPS not working & consumed.	[Signature]	[Signature]
02-08-15	New ups Replaced SS- INFOTECH SL-NO: 4061500010540	[Signature]	[Signature]
30-11-15	CPU is not working properly	[Signature]	[Signature]
30-11-15	Replaced with other CPU.	[Signature]	[Signature]
21/06/17	Keyboard keys not working properly.	[Signature]	[Signature]
21/06/17	New keyboard replaced S: NO: 1504540344488	[Signature]	[Signature]
09-11-17	System is not working & informed	[Signature]	[Signature]
09-11-17	Checked disc- volume & C.S he installed.	[Signature]	[Signature]
15-11-17	Monitor not working properly.	[Signature]	[Signature]
15-11-17	Replaced with other monitor MNT3 F560143618363300 SNO: 63600694231	[Signature]	[Signature]
02-12-18	ups not working properly (Battery backup)	[Signature]	[Signature]
T-12-18	UPS - Rich ups Replaced ups: ZEBCE079-0071808971	[Signature]	[Signature]

**FURNITURE MAINTENANCE REGISTER**

<p>16/3/17 DEPT. OF PERIODONTICS</p> <ol style="list-style-type: none"> <li>POSTER BOARDS FIXED - 15 NOS.</li> <li>SMALL POSTERS BOARD - 3 NOS.</li> <li>LOBBY (CEPT) - 2 NOS.</li> <li>DEPT BOARDS - 2 NOS.</li> <li>NOTICE BOARDS - 5 NOS.</li> <li>CLOCK - 1 NO.</li> <li>Hardware - 1 NO.</li> <li>MISC SCREWS - 15 NOS.</li> <li>REMOVED ALL ABOVE ITEMS FROM FIRST FLOOR &amp; FIXED IN SECOND FLOOR</li> <li>PLASTER DISPENSERS REMOVED</li> <li>OTHER ITEMS TO BE FIXED ON A LATER DATE</li> </ol> <p>Demapped lock removed &amp; new lock fixed in Dept of Minors. Steel cabinet.</p> <p>Shankaran 17/3/17</p>	<p>17/3/17 Department of Pathology</p> <p>Latex repair for the dental chair</p> <p>(98438842) 17/3/17</p> <p>17/3/17 DEPT. OF ORTHODONTICS</p> <ol style="list-style-type: none"> <li>Towel Hanger removed - 1 no.</li> <li>Soap and plate fixing - 3 nos.</li> <li>Towel Hanger fixing - 1 no.</li> </ol> <p>BDS Girls Hostel</p> <p>17-3-17 S25, S28, 31 Door Stopper fixed</p> <p>S28, Bathroom door repair work</p> <p>S23, Door stopper fixed</p> <p>BDS Girls Hostel</p> <p>Ground Floor Canteen door stopper fixed</p> <p>F14, F15 door stopper fixed.</p> <p>S2, S4, S1340</p>
---	--



Tagore dental college and hospital, Rathinamangalam, Tamil Nadu 600048, India

**Rathinamangalam**

Tamil Nadu

India

2019-12-11(Wed) 14:09

29°C

84°F

**BUILDING REPAIR AND MAINTENANCE:**

S.No	Date	Location	Work Details	Vendor	Amount
1	26.12.2017	Ground Floor-Surgery Ward, 2nd Floor-Girls Hostel and 3rd Floor-Seminar hall	False Ceiling	M/S. Mohanraj Enterprises	22,000.00
2	01.12.2017	Ground Floor-1st	Granite Cladding Work for Lift Area	M/S. The Chennai Granites	151,113.00
3	27.06.2018	Ground, Second and Third Floor (Surgery, DTH and OPD)	Supply and Fitting of Computer Table	M/S. Karaman & Team	2,00,000.00
4	21.02.2018	Near glass Room	Electric Cable Laying Work	M/S. Rajini & Team Members	3,400.00
5	08.05.2018	All Floors	Windows Lenses Work	M/S. Anand S. Chandrasekar	1,00,000.00
6	07.05.2018	All Floors	Cool work chiller ventilation work at 2nd floor	M/S. Mahalingam & Team Members	7,750.00
7	07.05.2018	1st floor	Comprehensive depth Aluminium partition painting work	M/S. A/Fire	11,700.00
8	19.02.2018	Terrace floor	RO Maintenance	S&S Tech	5,370.00
9	31.05.2018	Ground Floor	Girls hostel	Kunath painter	15,000.00
10	31.05.2018	Ground Floor	PG boys hostel- Ties supply	Aravindan Lumbayyan	77,440.00
11	03.2018	All Floors	Table correction work	Building reeling	60,100.00
12	19.5.2018	Ground floor	PG boys hostel- RO tank supply	Sureth Supplier	63,000.00
13	18.8.2018	1st floor	CR Transformer - Oil filling	Suresh Supplier	2,100.00
14	3.8.2018	Ground floor	PG boys hostel- Sand supply	Suresh Supplier	9,000.00
15	14.6.2018	Ground floor	PG boys hostel- Fitting supply	Asha Enterprises	21,000.00
16	14.6.2018	Ground floor	PG boys hostel- Fitting supply	Asha Enterprises	19,100.00
17	19.7.2018	Ground floor	girls hostel- dining wall removing	KSR Builders	10,000.00
18	10.7.2018	All Floors	Aluminium partition work	Jee Builders	373,160.00
19	10.7.2018	All Floors	Boys hostel- Carpentry work	AJ Hariprasad	79,770.00
20	10.7.2018	All Floors	Girls hostel- painting	Gobal Enterprises	75,210.00
21	19.7.2018	Ground floor	PG boys room- wall work	V.V.V. consultancy	152,000.00
22	19.7.2018	Ground floor	PG boys room- wall work	V.V.V. consultancy	79,100.00
23	18.2018	3rd floor	replace old P.V. window	Aravindan Lumbayyan	19,000.00
24	4.7.2018	Ground floor	North east handstage	AB Karpick	260,000.00
25	17.2018	terrace floor	Drainage connection	AB Karpick	600,000.00
26	4.7.2018	1st floor	Carpeting	sat hanna	60,000.00
27	3.8.2018	All Floors	PVC door supply	Aravindan Lumbayyan	5,000.00
28	9.7.2018	All Floors	Clean ducting work	Indraprasad painting	15,000.00
29	24.8.2018	All Floors	painting work	Kunath painter	9,870.00
30	13.7.2018	2nd floor	Grate repair	Hariprasad	7,000.00
31	1.8.2018	2nd floor	Aluminium partition work	Jee Builders	51,800.00
32	11.7.2018	Ground floor	False ceiling painting	Jee Builders	21,900.00
33	24.9.2018	All Floors	boys hostel- aluminium window	Aravindan Lumbayyan	64,000.00
34	18.8.2018	1st floor	Acid wash	M/S. Jayan	26,000.00
35	21.7.2018	2nd floor	Acid wash	Mr. Indu Kumar	26,650.00
36	25.10.2018	All Floors	sump work	AB Karpick	34,800.00
37	28.11.2018	ground floor	girls hostel- drainage tank liner remove	V. Lakshmi	4,000.00
38	9.11.2018	ground floor	PG dormitory work	Periyasamy	10,130.00
39	26.11.2018	All Floors	False ceiling work	Jee Builders	100,800.00
40	28.11.2018	ground floor	PG room retiling work-boys	Hariprasad	1,430.00
41	21.11.2018	All Floors	Boys hostel- ceiling work	V. Lakshmi	5,000.00
42	17.11.2018	1st floor	Aluminium partition work	Jee Builders	8,900.00
43	7.12.2018	Second floor and 3rd floor	painting work	Kunath painter	6,780.00
44	13.10.2018		M sand supply	Suresh Supplier	3,900.00
45	20.10.2018	Oil tank	pipe and supply	Suresh Supplier	21,500.00
46	20.10.2018	Car-park	base sand supply	Suresh Supplier	27,000.00
47	1.2.2019	1st floor	boys hostel final open rectification work	V. Lakshmi	13,200.00
48	18.4.2019	2nd floor & 3rd floor	Aluminium partition work	Aravindan Lumbayyan	19,200.00

**R.O SYTEM MAINTENANCE REGISTER:**

5487	18/12/19	plumbing dept. additional switch box work, switch box fixed, work is completed	plumbing dept. & staff
5488	18/12/19	R.O. plant work	college staff
5489	19/12/19	Boys hostel building collapse (a) Side pipe line leaking waste, (C waste water line), work is completed (b) Ground floor right side ayuthbasan pillar crack loose so fitting work, area is completed	Boys Hostel
5490	19/12/19	R.O plant pipe leaking work, so Replament pipe (base) work is completed	college staff
5491	20/12/19	ortho dept. HoD bathroom. washbasin. filler coat and. Connection hose Replament work, work is completed.	ortho dept.
5492	20/12/19	college P floor girls toilet block and ground floor Toilet boys and girls Toilet block waste, work is completed.	college
5493	20/12/19	R.O. plant work.	College staff

**SEWAGE TREATMENT PLANT MAINTENANCE REGISTER :**

<b>SEWAGE TREATMENT PLANT-350 KLD.</b> <b>TAGORE MEDICAL COLLEGE &amp; HOSPITAL</b> RATHINAMANGALAM, VANDALUR-KEAMBAKKAM ROAD, CHENNAI - 127 OPERATION LOG SHEET SHIFT DETAILS				
DATE	15.09.19			
DAY				
	SHIFT - I		SHIFT - II	
	ON	OFF	ON	OFF
BLOWER - I	Full working			
BLOWER - II				
BLOWER - III				
RAW WATER PUMP - I				
1. Near Store				
2. Near Gas Mainfold	8:00	3:00	12:00	2:00
3. Backside of Anatomy Lab			3:00	4:00
4. New Laundry			1:00	2:00
5. MBBS Boys Hostel			9:00	11:00
6. Staff Nurse Quarters			10:00	12:00
RAW WATER PUMP - II				
1. Old Laundry			11:00	4:00
2. New Hospital	7:00	4:00		1:00
3. Dental Boys Hostel	10:00	12:00		
4. Dental College	11:00	1:00		
5. MBBS Girls Hostel	2:00	4:00		
6. Staff Quarters - I	3:00	5:00		
7. Staff Quarters - II	7:00	2:00		
SLUDGE PUMP I				
SLUDGE PUMP II				
BACKWASH TIMING	9:00	9:30		
TREATED PUMP I				
<b>DOSING DETAILS</b>				
Sodium Hypo Chloride	2L			
MLSS				
PH of Raw Water				
Ph of Treated Water				
Remarks :				
Operation Name				
Signature of Supervisor				
Signature of Engineer				